

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0026:238 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Simplex Time Recorder, 100 Simplex Drive, Wetminster, MA 01441-0001
Contact: Paul D. Mattern (508) 632-2500, Ext 3388.

DESIGN: Model 4901-9820 *(*TrueAlert non-addressable*), 4901-9850 and 4901-9853 *(*True Alert addressable*) electronic horns. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electronic horn for use with separately listed electrically compatible fire alarm control units. For indoor use only.

This unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996.

*Rev. 10-12-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager